

FRANKLIN COUNTY, FLORIDA

ORDINANCE NO. 92-2

AN ORDINANCE ADOPTING A MORE STRINGENT STANDARD FOR THE MINIMUM SIZE OF ELECTRICAL CIRCUIT WIRING IN FRANKLIN COUNTY.

WHEREAS, the minimum size electrical wiring allowed by the National Electric Code 1990, adopted pursuant to Sections 389.539 and 553.19, Florida Statutes, is 14 gauge or size 14, and

WHEREAS, the Franklin County Board of County Commissioners has determined, pursuant to Section 533.18, Florida Statutes, that the minimum size circuit wiring should be 12 gauge or size 12,

NOW, THEREFORE, BE IT ORDAINED BY THE FRANKLIN COUNTY BOARD OF COUNTY COMMISSIONERS, FRANKLIN COUNTY, FLORIDA, that:

1. Notwithstanding anything in the National Electric Code 1990, the minimum size circuit wiring which may be installed in Franklin County shall be 12 gauge or size 12.

2. Wherever the National Electric Code, or the State of Florida Electric Code provides for a larger size circuit wire, the larger wire shall be installed.

This Ordinance adopted in open regular meeting this 21st day of April, 1992, after notice of intent to consider same has been made and kept in the Ordinance Book of the Clerk of the Board for at least fifteen (15) days, exclusive of Sundays and legal holidays, and the title and substance hereof published according to law in the Apalachicola Times, a newspaper of general circulation within the county.

This Ordinance shall take effect when notice of a receipt of a certified copy of same is returned from the Secretary of State.



THE BOARD OF COUNTY COMMISSIONERS OF FRANKLIN COUNTY, FLORIDA.

BY: Buford E. Braxton
Chairman

ATTEST:
Lee R. P. Rivers
Clerk